



VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx.
LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx.
WASHINGTON, DC: 540.636.9445 ph. | 540.636.9414 fx.
TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx.
TORONTO, ON: 416.550.9280
WEBSITE: WWW.QAI.ORG

January 31, 2019

Dear Mr. Tim Gentry,

QAI Laboratories Inc. has performed all the necessary tests to add Davinci Roofscapes Handsplit Shake siding to our QAI listing directory as being certified to ASTM D7254.

ASTM D7254 Section	Test	Result
5.2	Impact Resistance	Pass
5.3	Weathering	2-year weathering in progress*
5.4	Wind Load Resistance	Pass; able to withstand a minimum 16.2 psf static test pressure.
5.5	Surface Flame Spread	Pass; Flame Spread <200

*This product will preliminarily be certified based on evidence provided by Davinci that this product has been installed and in service without issue in multiple locations for multiple years until the official 2-year weathering is completed and the results included in the certification packet.

This product will be included under Davinci Roofscapes current listing B1050 in our system. After we have completed our internal administrative documentation process it will be published and made public in the QAI listing directory at www.QAI.org.

Once the certification is officially complete it will demonstrate that the Davinci Handsplit shake has met the requirements of the International Building Code (IBC), Section 1404.12 and 1405.18 and the International Roofing Code (IRC), Section R703.14 and Table R703.3(1).

QAI is accredited by the International Accreditation Service (IAS) as a third-party product certification body.

Best Regards,

Jason Friedrich, P.E.
Engineering Manager