

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

Page 1 of 1

**LISTING No.** 8180-2272:0500

**CATEGORY:** Non-Wood Roof Covering/Assemblies For Wildland Urban Interface (W.U.I)

**LISTEE:** Davinci Roofscapes, LLC, 13890 W. 101 St, Lenexa, KS 66215  
Contact: Tyler Newsome  
Email: tnewsome@davinciroofscapes.com

**DESIGN:** Davinci Roofscapes composite shake and slate roofing tiles. The roofing assembly consists of nominal 2"x4" Douglas Fir joists having a moisture content between 8-12%, 15/32" AC exterior grade plywood, single layer of Solarhide Roofing underlayment mechanically fastened to the deck using T50 staples at 18" O.C., Davinci composite shakes and slate fasten to deck using two 1-1/2" roofing nails per tile with 3/8" gap between each tile. Refer to manufacturer's installation, maintenance, operations guide for complete product details.

**RATING:** Class A Roof Covering

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product name and SFM label.

**APPROVAL:** \*Listed as a Class A roof covering assembly as described under "Design" for use in the Wildland Urban Interface areas. Refer to listee's Installation Instruction Manual for details.

\*Revision 09-17-20 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**

*Fire Engineering Division*

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

Page 1 of 1

**LISTING No.** 8140-2272:0501

**CATEGORY:** Exterior Wall Siding And Sheathing For Wildland Urban Interface (W.U.I)

**LISTEE:** Davinci Roofscapes, LLC, 13890 W. 101 St, Lenexa, KS 66215  
Contact: Tyler Newsome  
Email: tnewsome@davinciroofscapes.com

**DESIGN:** Davinci Handsplit Shake Siding. 8-10" W x 18" L x 5/8" butt thickness at maximum 8" shake exposure over 1/2" pressure treated FRT plywood with a water resistive barrier, ASTM D 226 Type 1 using 6d-1.75" siding nails 7-10 in. apart. Refer to manufacturer's installation, maintenance, operations guide for complete product details.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee name, Model number, rating and SFM label.

**APPROVAL:** Listed as Handsplit Shake Siding for use in the Wildland Urban Interface areas. Refer to listee's Installation Instruction Manual for details.

**NOTE:** SFM Standard 12-7A-1

12-10-19 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**

*Fire Engineering Division*